

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

URN No :- TC9964230000000233F

Dated: 24/06/2023

It is certified that an inspection team headed by **MR. ANIL KUMAR, QUALITY MANAGER/LAB ASSISTANT** from , **UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY** inspected the **JINGLE BELLS PUBLIC SCHOOL, CHHOTI BIHAR , PILIBHIT BY PASS ROAD, BAREILLY, UTTAR PRADESH** on **24/06/2023** (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. The above is valid for a period of **24/06/2023 to 23/06/2024**.

Signature with Seal:

Name :

Designation :

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :



(Rural) Bareilly.

To

MANAGER

JINGLE BELLS PUBLIC SCHOOL
CHHOTI BIHAR , PILIBHIT BY PASS
ROAD, BAREILLY, UTTAR PRADESH

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate, as a single pdf.

Analysis Report						
District Level Water Analysis Laboratory U.P.Jal Nigam (RURAL)						
Near M.B.Inter Collage, Gandhi Nagar, Bareilly (U.P.)						
 						
URN No :- TC996423000000233F						
Customer Details						
Office Name and Address	JINGLE BELLS PUBLIC SCHOOL, PILIBHIT BYPASS ROAD, BAREILLY					
Ref Letter No & Date	0 DATE - 23.06.2023 Report No.- LAB/BLY/2023-24/233					
Basic details of sample						
District	BAREILLY	Tehseel	BAREILLY	Analysis Start Date	24.06.2024	
Village	CHHOTI VIHAR	Block				
Habitation	NEAR FUN CITY	Location	IN SCHOOL	Analysis Completion Date	24.06.2024	
Water Source	SUBMERSIBLE	Sample Code	PS-233			
Quantity of Sample	2 ltr	Date of Sample Collection	24.06.2024	Report Issue Date	24.06.2024	
Receiving Date	24.06.2024	Sample Collector	VIJAY PAL	Sample Depositor	VIJAY PAL	
Environmental Condition						
Temperature		25± 2 oC		Humidity		
				50 ± 10%		
Technical Data of Analysis						
S.No.	Analysis Parameter	Unit of Measure ment	Observed Value	Specified Values as per IS 10500:2012		Ref.Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Colour	(Hazen)	1	5	15	IS 3025 (Part 4):2021
2	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022
3	Taste	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022
4	Turbidity	(NTU)	0.36	1.00	5.00	IS 3025 (Part 10) : 2022
5	TDS	(mg/L)	204	500	2000	IS 3025 (Part 16) : 2022
6	PH	-	7.81	6.5-8.5	6.5-8.5	IS 3025 (Part 11) : 2022
7	Iron	(mg/L)	0.2	1.00	1.00	IS:3025(Part-53):2014
8	Sulphate	(mg/L)	13.4	200	400	IS 3025 (Part 24) : 2022
9	Alkalinity	(mg/L)	178	200	600	IS 3025 (Part 23) : 2019
10	Hardness	(mg/L)	160	200	600	IS 3025 (Part 21) : 2019
11	Chloride	(mg/L)	7	250	1000	IS 3025 (Part 32) : 2019
12	Calcium	(mg/L)	44	75	200	IS:3025(Part-40):2019
13	Magnesium	(mg/L)	28.1	30	100	APHA 23 Edition 3500Mg Method B
Note						
1. This Certificate refers only to the particular sample(s) submitted for testing.						
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.						
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.						
4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.						
REMARK : - WATER IS POTABLE						

Page no:-1/1

Email - anamika05anu@gmail.com
U.P.J.N.BAREILLY (RURAL) Cont.No:- 7318253236

Prepared By

अनिल कुमार
गुणवत्ता प्रबन्धक
जल विश्लेषण प्रयोगशाला
उ० प्र० जल निगम बरेली (ग्रामीण)

Approved By



WATER ANALYSIS LABORATORY
U.P.JAL NIGAM BAREILLY (RURAL)
ADD :- Near M.B.Inter Collage Gandhi Nagar Bareilly - 243122 .

Sample No :- PS-233

Testing Date :- 24.06.2023

URN No :- TC9964230000000233F

Report No :- LAB/BLY/2023-24/233

It is certified that the water sample sent by JINGLE BELLS PUBLIC SCHOOL, PILIBHIT BYPASS ROAD, BAREILLY has been tested in the laboratory of Uttar Pradesh Jal Nigam (Rural) Bareilly, which is completely pure and drinkable for students and other employees.

The test report of the water sample tested in the laboratory has been given to the school premises.

I wish the students a bright future.


(Quality Manager)

अनिल कुमार
गुणवत्ता प्रबन्धक
जल विश्लेषण प्रयोगशाला
जल प्रो. जल निगम बरेली (ग्रामीण)

